



- LEGEND**
- (A) 10W, 1100lm, 3000K, 220V, IP54, LED RECESSED DOWNLIGHTER AS TAMELITE LIGHTING ASTRO AST110WW
 - (B) 20W, 2250lm, 3000K, 220V, IP20, LED PENDANT AS TAMELITE LIGHTING GEMINI GEM225WWW
 - (C) 3X10W LED DIMMABLE, IP20 3ARM PENDANT LIGHT IN AGED BRASS AS AMOS LIGHTING FRANKLITE POLARIS 3It.
 - (D) 25W, 3000lm, 4000K, 220V, IP65, LED BULKHEAD C/W EMERGENCY SELF TEST AS TAMELITE LIGHTING SOLAR S SLRS300NWWA3
 - (E) 19W, 2200lm, 4000K, 220V, IP65, LED BULKHEAD AS TAMELITE LIGHTING SOLAR S SLRS220NWW
 - (H) 10W LED DIMMABLE, IP20 WALL LIGHT IN AGED BRASS AS AMOS LIGHTING FRANKLITE POLARIS WALL LIGHT
 - (K) 15W LED DIMMABLE, IP20 WALL LIGHT IN AGED BRASS AS AMOS LIGHTING FRANKLITE POLARIS WALL LIGHT
 - (F) 28W, 4300lm, 3000K, 220V, IP20, LED SURFACE LINEAR FITTING AS TAMELITE LIGHTING PRIMA TMP04430WW
 - (EXIT) EMERGENCY EXIT SIGN
 - (Ng) 1G 1W SWITCH
 - (Ng) 2W SWITCH. Ng DENOTES NUMBER OF GANGS
 - (Ng) INTERMEDIATE SWITCH. Ng DENOTES NUMBER OF GANGS
 - (PD) PRESENCE DETECTOR (CEILING/ WALL MOUNTED)
 - (AD) ABSENCE DETECTOR (CEILING/ WALL MOUNTED)
 - (PIR) PIR PRESENCE DETECTOR (CEILING/ WALL MOUNTED)
- ABBREVIATIONS**
- E 3hr EMERGENCY
 - D DIMMER

© COPYRIGHT EDP:
THIS DRAWING REMAINS THE PROPERTY OF EDP ENVIRONMENTAL.
NOTE: DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS SHALL BE CHECKED ON SITE. ONLY FIGURED DIMENSIONS SHALL BE USED.
IF IN DOUBT, ASK.
THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL RELEVANT DRAWINGS, DOCUMENTS AND INFORMATION PREPARED BY THE ARCHITECT, OTHER CONSULTANTS AND SPECIALISTS.
THIS DRAWING SHALL BE READ IN CONJUNCTION WITH EDP ENVIRONMENTAL MECHANICAL & ELECTRICAL SERVICES SPECIFICATION & TECHNICAL SCHEDULES

HEALTH & SAFETY
STANDARD CONSTRUCTION HAZARDS THAT A COMPETENT CONTRACTOR WOULD BE AWARE OF DURING NORMAL WORKING PRACTICES ARE NOT IDENTIFIED ON THIS DRAWING.
RISKS THAT MAY NOT BE IMMEDIATELY APPARENT ARE LISTED BELOW.

REV	DATE	REVISION DESCRIPTION
P01	22.08.2025	INITIAL ISSUE

SCHEDULE OF REVISIONS

Architects Model:
Structural Model:
Other Model:
Model Schedule Key: [Discipline] [Date Received] [Revision] [Specific Model Number]

EDP
ENVIRONMENTAL

HEAD OFFICE
EMBLEM HOUSE
PYNES HILL
EXETER, EX2 5BA
EXETER T: 01392 367 237
BRISTOL T: 01173 258 975
FAREHAM T: 01329 800 710
LONDON T: 02076 091 899
CHOBHAM T: 01276 300 280

CLIENT:
COUNCIL OF THE ISLE OF SCILLY

PROJECT:
PARK HOUSE, ISLES OF SCILLY

DRAWING TITLE:
LIGHTING LAYOUT

GROUND FLOOR

SERVICE TYPE:
ELECTRICAL

DRAWING STATUS CODE:
REVIEW AND COMMENT

SCALE @ A1
1:50

INTERNAL PROJECT REF:
2606

DRAWING NUMBER:
2606-EDP-XX-00-DR-E-1000

PROJECT NUMBER - ORIGINATOR - ZONE - LEVEL - TYPE - ROLE - SEQUENTIAL NUMBER

Designed by: AT | Drawn by: AT | Checked by: CH | Revision: P01