



- LEGEND
- MSB BOARD
 - DISTRIBUTION BOARD
 - AC ISOLATOR - SINGLE PHASE
 - DC ISOLATOR
 - PV METER
 - G98 PANEL
 - INVERTER
 - CABLE TRAY MEDIUM DUTY
 - DC CABLE TRAY 50mm WIDE MEDIUM DUTY

© COPYRIGHT EDP:
THIS DRAWING REMAINS THE PROPERTY OF EDP ENVIRONMENTAL.
NOTE: DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS SHALL BE CHECKED ON SITE. ONLY FIGURED DIMENSIONS SHALL BE USED. IF IN DOUBT, ASK.
THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL RELEVANT DRAWINGS, DOCUMENTS AND INFORMATION PREPARED BY THE ARCHITECT, OTHER CONSULTANTS AND SPECIALISTS.
THIS DRAWING SHALL BE READ IN CONJUNCTION WITH EDP ENVIRONMENTAL MECHANICAL & ELECTRICAL SERVICES SPECIFICATION & TECHNICAL SCHEDULES

HEALTH & SAFETY
STANDARD CONSTRUCTION HAZARDS THAT A COMPETENT CONTRACTOR WOULD BE AWARE OF DURING NORMAL WORKING PRACTICES ARE NOT IDENTIFIED ON THIS DRAWING.
RISKS THAT MAY NOT BE IMMEDIATELY APPARENT ARE LISTED BELOW.

P02	22.02.2025	LAYOUT UPDATED
P01	26.02.2025	INITIAL ISSUE
REV	DATE	REVISION DESCRIPTION
SCHEDULE OF REVISIONS		

Architects Model:
Structural Model:
Other Model:
Model Schedule Key: [Discipline] _ [Date Received] _ [Revision] _ [Specific Model Number]



HEAD OFFICE
EMBLEM HOUSE
PYNES HILL
EXETER, EX2 5BA
EXETER T: 01392 367 237
BRISTOL T: 01173 258 975
FAREHAM T: 01329 800 710
LONDON T: 02076 091 899
CHOBHAM T: 01276 300 280

CLIENT:
COUNCIL OF THE ISLES OF SCILLY

PROJECT:
PARK HOUSE, ISLE OF SCILLY
DRAWING TITLE:
ELECTRICAL DISTRIBUTION

FIRST FLOOR
SERVICE TYPE:
ELECTRICAL
DRAWING STATUS CODE:
REVIEW AND COMMENT

SCALE @ A1 1:50 | INTERNAL PROJECT REF: 2606

DRAWING NUMBER:
2606-EDP-XX-01-DR-E-6001
PROJECT NUMBER - ORIGINATOR - ZONE - LEVEL - TYPE - ROLE - SEQUENTIAL NUMBER

Designed by: CH | Drawn by: CH | Checked by: SWR | Revision: P02