





NOTES

- THIS DRAWING IS NOT TO BE USED FOR CONSTRUCTION UNLESS MARKED ABOVE "FOR CONSTRUCTION"
- THE COPYRIGHT ON THIS DRAWING IS RETAINED BY MICHAEL BEARDSALL ASSOCIATES LTD
- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTS AND ENGINEERS DRAWINGS AND SPECIFICATIONS
- THE CONTRACTOR IS RESPONSIBLE FOR ALL DIMENSIONS AND THE CORRECT SETTING OUT ON SITE. ONLY FIGURED DIMENSIONS ARE TO BE USED.
DO NOT SCALE : IF IN DOUBT ASK
DIMENSIONS SHOULD **NOT BE TAKEN** ELECTRONICALLY
- ALL MATERIALS AND WORKMANSHIP TO COMPLY WITH THE CURRENT BRITISH STANDARDS AND CODES OF PRACTICE
- ALL SET-OUT, LEVEL AND DIMENSIONAL INFORMATION SHOWN ON THIS AND ANY ASSOCIATED MBA DRAWINGS TO BE CONFIRMED AND APPROVED BY THE ARCHITECT PRIOR TO COMMENCEMENT OF ANY CONSTRUCTION OR FABRICATION WORKS. REFER TO THE ARCHITECT'S DRAWINGS FOR ALL LOCATIONS, EXTENTS, SPECIFICATIONS AND DETAILS OF DPM, WATERPROOFING, INSULATION & THERMAL BREAK LOCATIONS, FINISHES, FIRE PROTECTION (INCLUDING REQUIRED FIRE RESISTANCE PERIOD) AND MOVEMENT JOINTS
- FOUNDATIONS**
ALL FOUNDATIONS TO BEAR ONTO THE UNDERLYING BROWN & ORANGE BROWN CLAYEY SANDY SUBANGULAR MEDIUM GRAVEL OF GRANITE ENCOUNTERED AT DEPTHS BETWEEN 0.8 & 1.2m. REFER TO IAN FARMER ASSOCIATES LETTER REPORT "IOS SCHOOL - G51301" ISSUED 28TH SEPTEMBER 2017 FOR FURTHER DETAILS. LEVEL DIFFERENCE BETWEEN CUT EXCAVATION & MINIMUM FOUNDATION THICKNESS SPECIFIED TO BE MADE UP USING GEN 1 LEAN MIX CONCRETE FILL.
ALL MASS CONCRETE FOUNDATIONS TO BE GRADE GEN 3 & MIN. 225mm THK UNLESS NOTED OTHERWISE ON PLAN. ALL STRIP FOUNDATIONS TO BE CENTRED ON MASONRY WALL OVER. ALL STEEL COLUMNS BELOW GROUND LEVEL TO BE ENCASED IN GRADE C35 CONCRETE 100mm THK. WITH D49 WRAPPING FABRIC WITH 50mm COVER UP TO UNDERSIDE OF SLAB LEVEL.
- MASONRY**
ALL SUBSTRUCTURE MASONRY TO BE LIGHTWEIGHT 7.3N/mm² BLOCK LAID IN CLASS M6 (ii) MORTAR - TO BE TOOTH BONDED AT ALL INTERSECTIONS, BACKFILLING OF SUB STRUCTURAL WALLS TO BE CARRIED OUT SIMULTANEOUSLY ON EITHER SIDE TO PREVENT A RETAINING WALL SITUATION OCCURRING. MAX. MASONRY UNIT WEIGHT TO BE LIMITED TO 20kg.




SECTION 1 - CANOPY CROSS SECTION

SCALE 1:20




DETAIL A - CANOPY UPPER HEAD CONNECTION

SCALE 1:10




SECTION A-A

SCALE 1:10




DETAIL C - CANOPY FOOT CONNECTION

SCALE 1:10




SECTION B-B

SCALE 1:10



DETAIL B - CANOPY LOWER HEAD CONNECTION

SCALE 1:10



SECTION C-C

SCALE 1:10

P4	13.11.17	ISSUED FOR BUILDING REGS	DJ	EP
P3	09.11.17	ISSUED FOR TENDER	DJ	EP
P2	07.11.17	ISSUED FOR TENDER	DJ	EP
P1	27.10.17	ISSUED FOR TENDER	DJ	MH
	DATE	REVISION SUMMARY	BY	CHK

JOB TITLE:
CARN GWAVAL
CHURCH ROAD, ST MARY'S
ISLES OF SCILLY
TR21 0NA

CLIENT:
 COUNCIL OF THE ISLES OF SCILLY
TOWN HALL
ST MARY'S
ISLES OF SCILLY
TR21 0LW

DETAIL:
CANOPY
SECTIONS & DETAILS

DRN. BY: D JAMES

DATE: OCT 2017 SCALE: AS SHOWN @ A1

JOB NO: 16240 DRAWING No: 35 REV: P4

MBA
CONSULTING

Boscawen House · Chapel Hill · Truro · Cornwall
TR1 3BN
Tel. 01872 260962 Fax. 01872 260963