

Walton, Lisa

From: David Perry [David@wmweller.co.uk]
Sent: 12 May 2015 15:40
To: Walton, Lisa
Cc: peter@crha.org.uk
Subject: RE: Well Cross - Discharge of Planning Conditions P/14/026 FUL and P/14/027 FUL
Attachments: DG_18022015_M01 P2, 30032015.pdf; DG_18022015_E01 P2, 27032015.pdf

Dear Lisa

Attached submission for the discharge of conditions 8 and 18 for P/14/026 FUL.

Condition 8 - Details of sustainable measures - Drawing E01 P2 and M01 P2 detail the proposals in connection with the mechanical and electrical installations. Notably; low energy LED down-lights, Solar Thermal Panel, flow restrictors to limit the water usage, Dual- flush WC and heat recovery units. In addition rainwater butts connected to the downpipes will be provided to each property.

Condition 18 - Mechanical and ventilation/extraction treatments – Drawing M01 P2 detail the proposals in connection with the mechanical and electrical installations.

Solar panels have been positioned appropriately and co-ordinated with the structural limitation of the roof.

With regard to condition 17 boundary treatments Peter Moore and I will be reviewing on our next visit then submitting a proposal.

Should you require further detail please do not hesitate to contact me.

Regards

David Perry MRICS
Director
For and On Behalf of:
Wm G Weller & Son Ltd
Chartered Quantity Surveyors
Trecarrel
Drump Road
Redruth
Cornwall
TR15 1LU

Tel: (01209) 215621
Fax: (01209) 210357
e-mail: david@wmweller.co.uk

Please visit our new website at www.wmweller.co.uk

