

## **King, Andrew**

---

**From:** Thompson,Matthew

**Sent:** 28 December 2016 21:20

**To:** King, Andrew

**Cc:** Dryden, Craig; Pearce,Helen; Walton,Lisa

**Subject:** Re: Weekly Planning List

Hi Andrew,

The location is where I envisaged and will be an extremely awkward property to connect to the mains distribution network. The options are limited, but not impossible, to get this site connected.

What also concerns me is the large supply main from Buzza Reservoir which feeds all of rams valley through Porthcressa to Sallyport runs in the footpath next to the site, this main dates back to the 30s-40s and is cast iron in construction and is in an extremely poor condition, any heavy machinery or building works which could take place next to it needs to be avoided where possible as any disturbance will result in major disruption to the main leading to vast consumer complaints.

Matt Thompson

Officer: Water

Council of the Isles of Scilly, Town Hall, St Marys, Isles of Scilly, TR21 0LW