



CERTIFICATE FOR IDENTIFICATION OF ASBESTOS FIBRES

STANDARD
PREMIUM
EMERGENCY

Client:	STERLING TECHNICAL SERVICES LTD	Analysis Report No.	SCO/13/33353				
Address:	80 BOND STREET HOUNDSTONE YEOVIL BA22 8SP		Report Date:	20/11/13			
Attention:	R H DUDSON			Site Ref No.	ST/916		
Site Address:	IMPLEMENT SHED MIDDLE TINKS COTTAGE HAY VALE ST MARYS ISLES OF SCILLY TR21 0NT		Page No:		1	Of	1
Date sample taken:	17/11/13				No. of Samples:	1	
Date sample received:	20/11/13		Obtained:	DELIVERED			
Date of Analysis:	20/11/13						

Samples of material, referenced below, have been examined to determine the presence of asbestos fibres, using Scopes Asbestos Analysis "in house" method of transmitted/polarised light microscopy and centre stop dispersion staining, based on HSE's HSG248. If samples have been DELIVERED the site address and actual sample location is as given by the client at the time of delivery. Scopes Asbestos Analysis Services Limited are not responsible for the accuracy or competence of the sampling by third parties. Under these circumstances Scopes Asbestos Analysis Services Limited cannot be held responsible for the interpretation of the results shown.

SCOPE S SAMPLE No.	CLIENT SAMPLE No.	Sample Location	Fibre Type Detected
1	1	SHED ROOF - ROOFING SHEET	CHRYSTOLE

KEY: NADIS - No Asbestos Detected in Sample

Note: All samples will be retained for a minimum of six months.

Note: This Certificate for Identification of Asbestos Fibres shall not be reproduced except in full without the written approval of the Laboratory.

Analysed by:	W.JEfferies	Authorised signatory:	
		Print name:	S BOLTON- Q.C.M

BULK 001-VER 5 12-AUGUST-09-QCM