

Council of the Isles of Scilly Planning Application

Ref: P/21/068/HH

*

Consultation Response

Date: 20th August 2021

Ref: P/21/068/HH

Site: 6 Bay View Terrace, Telegraph Road, St Mary's

Proposal: Re-build first floor extension, replace windows and doors and alterations and improvements.

You are being consulted on this application as you may wish to make comments before a decision is made. Should you wish to make any comments on this application, please complete the response form below and return to planning@scilly.gov.uk by 13th September 2021 or by post to the Planning Department, Town Hall, The Parade, Hugh Town, St Mary's, Isles of Scilly TR21 0LW.

Link to application: <https://www.scilly.gov.uk/planning-application/planning-application-p21068hh>

I look forward to receiving your comments in due course. If I have not heard back from you by the 13th September 2021 then I will assume you have no comments to make.

Consultee Name:

[Comments here](#)

Access and Facilities for the Fire Service as detailed in B5 ADB Volume 1 will be required. For dwellinghouses access for a pumping appliance should be provided to within 45m of all points inside the dwellinghouse.

It is important to remember that failure to do so may prevent the applicant from obtaining a completion certificate under the Building Regulations but more importantly, the lives of the occupiers will be put at risk.

Name: Darren Vincent (Business Fire Safety Officer Cornwall Fire & Rescue Service)

Date: 23rd August 2021